

INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE	2024/4/22	CATEGORY	GENERATOR / COMPRESSOR / WELDER		
MAKE	DENYO		MODEL	DCA-13LSYB	
SERIAL	3915491		STAMP	NOT FOUND	
HR METER	8989	HR	TIRE SIZE	YEAR	YR

ENGINE :	MODEL	3TNV84	S/N	64877		
Oil leakage	FAIR	Attn	Oil	FAIR	Attn	
Blow-By	FAIR	Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	FAIR · Attn	白煙あり WHITE FUMES
Sound	FAIR	Attn	Radiator	FAIR	Attn	

GENERATOR					
RATED POWER	10.5 / 13.0	KVA	Leaking Breaker Condition	FAIR	Attn
RATED AMPERE	30.3 / 34.1	A	Insulation Condition	FAIR	Attn
Output Terminal	FAIR	Attn			

COMPRESSOR					
RATED PRESSURE		Mpa Kgf/cm2	Unload Condition	FAIR	Attn
RATED AIR FLOW		m3/min	Receiver Tank Condition	FAIR	Attn
Compressor Oil Leak	FAIR	Attn	Safety Valve Condition	FAIR	Attn

CONDITION	FAIR	Attn
-----------	------	------

RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3
--	---

COMMENTS

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.
この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。