

INSPECTION SHEET 検品書
GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダ

INSPECTION DATE	2024/10/28	CATEGORY	GENERATOR / COMPRESSOR / WELDER		
MAKE	SHIN DAIWA		MODEL	DGM250MK-P	
SERIAL	D13755000988		STAMP	NOT FOUND	
HR METER	14444	HR	TIRE SIZE	YEAR	YR

ENGINE :	MODEL	V2403	S/N	7FG8163
Oil leakage	<input checked="" type="radio"/> FAIR · Attn		Oil	<input checked="" type="radio"/> FAIR · Attn
Blow-By	<input checked="" type="radio"/> FAIR · Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	<input checked="" type="radio"/> FAIR · Attn
Sound	<input checked="" type="radio"/> FAIR · Attn		Radiator	<input checked="" type="radio"/> FAIR · Attn

GENERATOR				
RATED POWER	20 / 25	KVA	Leaking Breaker Condition	<input checked="" type="radio"/> FAIR · Attn
RATED AMPERE	57.7 / 65.6	A	Insulation Condition	<input checked="" type="radio"/> FAIR · Attn
Output Terminal	<input checked="" type="radio"/> FAIR · Attn			

COMPRESSOR				
RATED PRESSURE		Mpa Kgf/cm2	Unload Condition	<input checked="" type="radio"/> FAIR · Attn
RATED AIR FLOW		m3/min	Receiver Tank Condition	<input checked="" type="radio"/> FAIR · Attn
Compressor Oil Leak	<input checked="" type="radio"/> FAIR · Attn		Safety Valve Condition	<input checked="" type="radio"/> FAIR · Attn

CONDITION	<input checked="" type="radio"/> FAIR · Attn	

RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	
--	---	--

COMMENTS

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

.....

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.
この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。