INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機･コンプレッサー･ウェルダー

INSPECTION DATE	2024/10/16	CATEGORY	(GENERATOR) / COMPRESSOR / WELDER		
MAKE	DENYO		MODEL	DCA-60LSIB	
SERIAL	3900077		STAMP	NOT FOUND	
HR METER	20021 HR	TIRE SIZE		YEAR	YR

ENGINE :	MODEL	4JJ1	S/N	192047	
Oil leakage	(FAIR) · Attn		Oil	(FAIR) · Attn	
Blow-By	(FAIR) · Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	(FAIR) · Attn	
Sound	(FAIR) · Attn		Radiator	(FAIR) · Attn	

GENERATOR					
RATED POWER	50 / 60	KVA	Leaking Breaker Condition	(FAIR) · Attn	
RATED AMPERE	144, 72.2 / 157, 78.7	A	Insulation Condition	(FAIR) · Attn	
Output Terminal	(FAIR) · Attn				

COMPRESSOR					
RATED PRESSURE	Mpa Kgf/cm2		Unload Condition	FAIR · Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR · Attn	
Compressor Oil Leak	FAIR · Attn		Safety Valve Condition	FAIR · Attn	

CONDITION	(FAIR) · Attn	

RUST(5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	

COMMENTS

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。