INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE	2024/10/28	CATEGORY	GENERATOR / COMPRESSOR / WELDER		
MAKE	DENYO		MODEL	DLW-200X2LS	
SERIAL	5670019		STAMP	NOT FOUND	
HR METER	1939 HR	TIRE SIZE		YEAR	YR

ENGINE :	MODEL	D902	S/N	BY0961	
Oil leakage	FAIR・Attn		Oil	FAIR・Attn	
Blow-By	FAIR・Attn	A LITTLE ・MIDDLE ・SEVERE	Exhaust Color	FAIR・Attn	
Sound	FAIR・Attn		Radiator	FAIR・Attn	

GENERATOR					
RATED POWER	7.0, 7.7 / 10.7, 11.8 KVA		Leaking Breaker Condition	FAIR・Attn	
RATED AMPERE	30A×1, 15A×4 / 31, 31 A		Insulation Condition	FAIR・Attn	
Output Terminal	FAIR・Attn				

COMPRESSOR					
RATED PRESSURE	Mpa Kgf/cm2		Unload Condition	FAIR・Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR・Attn	
Compressor Oil Leak	FAIR・Attn		Safety Valve Condition	FAIR・Attn	

CONDITION	FAIR・Attn	

RUST(5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	

COMMENTS

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。