INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE	2024/3/18	CATEGORY	GENERATOR / COMPRESSOR / WELDER		
MAKE	DENYO		MODEL	DCA-13LSYB	
SERIAL	3915498		STAMP	NOT FOUND	
HR METER	14442 HR	TIRE SIZE		YEAR	YR

ENGINE :	MODEL	3TNV84	S/N	64864	
Oil leakage	FAIR・Attn		Oil	FAIR・Attn	
Blow-By	FAIR・Attn	A LITTLE ・MIDDLE ・SEVERE	Exhaust Color	FAIR・Attn	
Sound	FAIR・Attn		Radiator	FAIR・Attn	

GENERATOR					
RATED POWER	10.5 / 13.0	KVA	Leaking Breaker Condition	FAIR・Attn	
RATED AMPERE	30.3 / 34.1	A	Insulation Condition	FAIR・Attn	
Output Terminal	FAIR・Attn				

COMPRESSOR					
RATED PRESSURE	Mpa Kgf/cm2		Unload Condition	FAIR・Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR・Attn	
Compressor Oil Leak	FAIR・Attn		Safety Valve Condition	FAIR・Attn	

CONDITION	FAIR・Attn	

RUST(5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	

COMMENTS

パネルFカバー閉まらない OPERATION PANEL COVER: UNABLE TO SHUT

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。