

INSPECTION SHEET 検品書  
GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE	2024/4/16	CATEGORY	GENERATOR / COMPRESSOR / WELDER		
MAKE	DENYO		MODEL	DCA-150ESM	
SERIAL	3851534		STAMP	NOT FOUND	
HR METER	1793	HR	TIRE SIZE	YEAR	YR

ENGINE :	MODEL	MITSUBISHI 6D16-TLE2D	S/N	
Oil leakage	FAIR Attn		Oil	FAIR Attn
Blow-By	FAIR Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	FAIR Attn
Sound	FAIR Attn		Radiator	FAIR Attn

<b>GENERATOR</b>				
RATED POWER	125 / 150	KVA	Leaking Breaker Condition	FAIR Attn
RATED AMPERE	361, 180 / 394, 197	A	Insulation Condition	FAIR Attn
Output Terminal	FAIR Attn			

<b>COMPRESSOR</b>				
RATED PRESSURE		Mpa Kg/cm2	Unload Condition	FAIR Attn
RATED AIR FLOW		m3/min	Receiver Tank Condition	FAIR Attn
Compressor Oil Leak	FAIR Attn		Safety Valve Condition	FAIR Attn

CONDITION	FAIR Attn	
-----------	-----------	--

RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	
--	---	--

<b>COMMENTS</b> 非常停止ボタン故障あり EMERGENCY STOP BUTTON: MALFUNCTION          
---

This inspection information is for reference only at “the inspection date” by SOGO. NOT to guarantee the condition of the actual machine.  
この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。