

INSPECTION SHEET 検品書
GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダ

INSPECTION DATE	2024/4/30	CATEGORY	GENERATOR / COMPRESSOR / WELDER		
MAKE	DENYO		MODEL	DCA-25LSKB	
SERIAL	3905409		STAMP	NOT FOUND	
HR METER	16506	HR	TIRE SIZE	YEAR	YR

ENGINE :		MODEL	V2403	S/N	7FY3635
Oil leakage	FAIR · Attn	ヘッドカバーにじみあり HEAD COVER: OIL Oozing		Oil	FAIR · Attn
Blow-By	FAIR · Attn	A LITTLE · MIDDLE · SEVERE		Exhaust Color	FAIR · Attn
Sound	FAIR · Attn			Radiator	FAIR · Attn

GENERATOR					
RATED POWER	20.0 / 25.0	KVA	Leaking Breaker Condition	FAIR · Attn	
RATED AMPERE	57.7 / 65.6	A	Insulation Condition	FAIR · Attn	
Output Terminal	FAIR · Attn				

COMPRESSOR					
RATED PRESSURE		Mpa Kgf/cm2	Unload Condition	FAIR · Attn	
RATED AIR FLOW		m3/min	Receiver Tank Condition	FAIR · Attn	
Compressor Oil Leak	FAIR · Attn		Safety Valve Condition	FAIR · Attn	

CONDITION	FAIR · Attn				

RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	4				
---	---	--	--	--	--

COMMENTS					
-----------------	--	--	--	--	--

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.
 この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。