INSPECTION SHEET 検品書 GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE		2024/4/25		CATEGORY		GENER	RATOR	COMPRESSOR / WELDER		
MAKE		NIPPON SHARYO			MODEL		NES45TYL3			
SERIAL		AX014100			STAMP		NOT FOUND			
HR METER		13865	HR	TIRE SIZ	E			YEAR		YR
ENGINE :	MOD)EL	4T	NV98T		S/N				
Oil leakage	FAIR · Attn					Oil	FAIR • Attn			
Blow-By FAIR · Attn		A LITTLE • MIDDLE • SEVERE			Exhaust Color	FAIR • Attn	黒煙あ	り BLACK FU	JMES	
Sound	FAIR · Attn					Radiator	FAIR • Attn			
GENERATO	 DR									
RATED POWER		37 / 45 KVA			Leaking Breaker Condition FAIR • (Attn)*1					
RATED AMPERE		107, 53.	4 / 118, 5	9.0	Α	Insulation (Condition	FAIR •	Attn	
Output To	erminal	FAIR • Attn								
COMPRES	SOR									
RATED PRESSURE				Мра	Kgf/cm2	Unload C	ondition	FAIR •	Attn	
RATED AIR FLOW				m	n3/min	Receiver Tan	ık Condition	FAIR •	Attn	
Compressor Oil Leak		FAIR • Attn				Safety Valve	• Condition	FAIR •	Attn	
CONDI	TION	FAIR • Attn								
RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED) 3										
COMMENT										
*1 テストS/	/W不良、	未確認 NO	I CHECKE	ט (TEST S	WITCH:	MALFUNCT	ION)			

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine. この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。