INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE	2024/5/2	CATEGORY	(GENERATOR) / COMPRESSOR / WELDER		
MAKE	DENYO		MODEL	DCA-150LSKE	
SERIAL	3909984		STAMP	NOT FOUND	
HR METER	5642 HR	TIRE SIZE		YEAR	YR

ENGINE :	MODEL	6D107E-1	S/N	26650954	
Oil leakage	(FAIR) · Attn		Oil	(FAIR) · Attn	
Blow-By	(FAIR) · Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	(FAIR) · Attn	
Sound	(FAIR) · Attn		Radiator	(FAIR) · Attn	

GENERATOR					
RATED POWER	125 / 150	KVA	Leaking Breaker Condition	(FAIR) · Attn	
RATED AMPERE	361, 180 / 394, 197	A	Insulation Condition	(FAIR) · Attn	
Output Terminal	(FAIR) · Attn				

COMPRESSOR					
RATED PRESSURE	Mpa Kgf/cm2		Unload Condition	FAIR · Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR · Attn	
Compressor Oil Leak	FAIR · Attn		Safety Valve Condition	FAIR · Attn	

CONDITION	FAIR · (Attn)	

60Hzダイヤルで55Hzまでしか上がらない UNABLE TO RISE TO 60Hz (MAX: 55Hz)

RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	

COMMENTS

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。