INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE	2024/6/19	CATEGORY	GENERATOR / COMPRESSOR / WELDER		
MAKE	AIRMAN		MODEL	PDS100SC-5C1	
SERIAL	B6C5C13169		STAMP	–	
HR METER	994 HR	TIRE SIZE		YEAR	YR

ENGINE : MODEL			S/N		
Oil leakage	FAIR・Attn		Oil	FAIR・Attn	
Blow-By	FAIR・Attn	A LITTLE ・MIDDLE ・SEVERE	Exhaust Color	FAIR・Attn	
Sound	FAIR・Attn		Radiator	FAIR・Attn	

GENERATOR					
RATED POWER	KVA		Leaking Breaker Condition	FAIR・Attn	
RATED AMPERE	A		Insulation Condition	FAIR・Attn	
Output Terminal	FAIR・Attn				

COMPRESSOR					
RATED PRESSURE	0.69 Mpa Kgf/cm2		Unload Condition	FAIR・Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR・Attn	
Compressor Oil Leak	FAIR・Attn		Safety Valve Condition	FAIR・Attn	

CONDITION	FAIR・Attn	

RUST(5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	

COMMENTS

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。