INSPECTION SHEET 検品書 GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE		2025/8/8		CATEGORY		GENERATOR COMPRESSOR / WELDE					.DER
MAKE		KOMATSU				MODEL		EG500BS-1			
SERIAL		3695752						NOT FOUND			
HR METER		2715	HR	TIRE SIZE				YEAR			YR
ENGINE :	MOD	S/N 19892									
Oil leakage	FAIR · Attn					Oil	FAIR • Attn				
Blow-By FAIR · Attn		A LITTLE • MIDDLE • SEVERE			Exhaust Color	FAIR • Attn					
Sound	FAIR · Attn					Radiator	FAIR • Attn	*1			
GENERATOR											
RATED POWER		450 / 500 KVA			.VA	Leaking Breaker Condition FAIR • Attn					
RATED AMPERE		1299, 650 / 1312, 656 A			Α	Insulation Condition FAIR - Attn					
Output Terminal		FAIR • Attn									
COMPRES	SOR										
RATED PRESSURE				Мра	Kgf/cm2	Unload C	ondition	FAIR •	Attn		
RATED AIR FLOW			m3/min			Receiver Tan					
Compressor Oil Leak		FAIR • Attn				Safety Valve Condition FAIR • Attn					
COND	TION	FAID . A.									
CONDITION [FAIR)・ Attn											
ハソナソ ^ー /攻小たフンフ 忌刃 のツ WAKNING LAMP FUK BATTEKY LUW LEVEL: UN											
<u> </u>											
RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CO			:: MUCH, 1: COF	RRODED)	4	TIRE WEA	R FA	IR • W	ORN · UN	IEVEN WEA	\R
COMMENT		# P+ + ' '	NDOLING 5	AD 14/4							
*! キャッブ	′ 周り水漏	れ跡あり メ	AKUUND C	AP: WATER I	LEAK 7	IRACE				***************************************	
						·····		·····	·····	·····	
·····											

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine. この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。