INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機・コンプレッサー・ウェルダー

INSPECTION DATE	2026/2/18	CATEGORY	GENERATOR (COMPRESSOR) WELDER		
MAKE	AIRMAN		MODEL	PDS70S	
SERIAL	70-5B10130		STAMP	NOT FOUND	
HR METER	985 HR	TIRE SIZE		YEAR	YR

ENGINE : MODEL S/N

Oil leakage	(FAIR) · Attn		Oil	(FAIR) · Attn	
Blow-By	(FAIR) · Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	FAIR · (Attn)	白煙中～大 MUCH WHITE FUMES
Sound	FAIR · (Attn)	異音あり NOISES	Radiator	(FAIR) · Attn	

GENERATOR

RATED POWER	KVA		Leaking Breaker Condition	FAIR · Attn	
RATED AMPERE	A		Insulation Condition	FAIR · Attn	
Output Terminal	FAIR · Attn				

COMPRESSOR

RATED PRESSURE	0.7 (MPa) Kgf/cm2		Unload Condition	(FAIR) · Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	(FAIR) · Attn	
Compressor Oil Leak	(FAIR) · Attn		Safety Valve Condition	(FAIR) · Attn	

CONDITION	FAIR · (Attn)

E/G故障あり、吹けない ENGINE: MALFUNCTION, UNABLE TO REV UP

RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	TIRE WEAR	FAIR ・WORN・ UNEVEN WEAR

COMMENTS

E/G故障のためアイドリング時の0.4MPaまでしか上がらない IDLE AIR PRESSURE: 0.4MPa (ENGINE: UNABLE TO REV UP)

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.
この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。