INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機･コンプレッサー･ウェルダー

INSPECTION DATE	2026/4/3	CATEGORY	(GENERATOR) / COMPRESSOR / WELDER		
MAKE	三友工業 SANYU		MODEL	SEGS160-225	
SERIAL	77391A002		STAMP	NOT FOUND	
HR METER	24 HR	TIRE SIZE		YEAR	YR

ENGINE : MODEL			S/N	7Y0976	
Oil leakage	(FAIR) · Attn		Oil	(FAIR) · Attn	
Blow-By	(FAIR) · Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	(FAIR) · Attn	
Sound	(FAIR) · Attn		Radiator	(FAIR) · Attn	

GENERATOR					
RATED POWER	5.0 KVA		Leaking Breaker Condition	FAIR · Attn	
RATED AMPERE	25 A		Insulation Condition	FAIR · Attn	
Output Terminal	FAIR · Attn				

COMPRESSOR					
RATED PRESSURE	Mpa Kgf/cm2		Unload Condition	FAIR · Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR · Attn	
Compressor Oil Leak	FAIR · Attn		Safety Valve Condition	FAIR · Attn	

CONDITION	(FAIR) · Attn	
バッテリー端子ボルト欠のため外部バッテリーで検品（本体バッテリー未確認）		
OPERATION: CHECKING WITH EXTERNAL BATTERY (BATTERY TERMINAL BOLT: MISSING, MAIN BATTERY: NOT CHECKED)		

RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	5	TIRE WEAR	FAIR · WORN · UNEVEN WEAR

COMMENTS

据置鉛蓄電池 VALVE-REGULATED STATIONARY LEAD-ACID BATTERY MAKE: FURUKAWA MSE-100-6-14767 (YEAR: 2021)

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.
この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。