# INSPECTION SHEET 検品書

## GENERATOR / COMPRESSOR / WELDER 発電機･コンプレッサー･ウェルダー

| | | | | | |
|---|---|---|---|---|---|
| INSPECTION DATE | 2026/4/17 | CATEGORY | (GENERATOR) / COMPRESSOR / WELDER | | |
| MAKE | NIPPON SHARYO | | MODEL | NES45TYL3 | |
| SERIAL | AX025900 | | STAMP | NOT FOUND | |
| HR METER | 16045 HR | TIRE SIZE | | YEAR | YR |

| ENGINE : | MODEL | YANMAR 4TNV98T | S/N | 128918 | |
|---|---|---|---|---|---|
| Oil leakage | FAIR ･ (Attn) | *1 | Oil | (FAIR) ･ Attn | |
| Blow-By | (FAIR) ･ Attn | A LITTLE ･ MIDDLE ･ SEVERE | Exhaust Color | (FAIR) ･ Attn | |
| Sound | (FAIR) ･ Attn | | Radiator | (FAIR) ･ Attn | |

| GENERATOR | | | | | |
|---|---|---|---|---|---|
| RATED POWER | 37 / 45 | KVA | Leaking Breaker Condition | (FAIR) ･ Attn | |
| RATED AMPERE | 107, 53.4 / 118, 59.0 | A | Insulation Condition | (FAIR) ･ Attn | |
| Output Terminal | (FAIR) ･ Attn | | | | |

| COMPRESSOR | | | | | |
|---|---|---|---|---|---|
| RATED PRESSURE | Mpa Kgf/cm2 | | Unload Condition | FAIR ･ Attn | |
| RATED AIR FLOW | m3/min | | Receiver Tank Condition | FAIR ･ Attn | |
| Compressor Oil Leak | FAIR ･ Attn | | Safety Valve Condition | FAIR ･ Attn | |

| CONDITION | (FAIR) ･ Attn | |
|---|---|---|
| | | |
| | | |

| RUST(5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED) | 4 | TIRE WEAR | FAIR ･ WORN ･ UNEVEN WEAR |
|---|---|---|---|

**COMMENTS**

*1 E/G周りパイプホースにじみあり SOME PIPE AROUND ENGINE: OIL OOZING

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。