INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機･コンプレッサー･ウェルダー

INSPECTION DATE	2026/4/18	CATEGORY	(GENERATOR) / COMPRESSOR / WELDER		
MAKE	NIPPON SHARYO		MODEL	NES60TKL2	
SERIAL	KT017100		STAMP	NOT FOUND	
HR METER	13268 HR	TIRE SIZE		YEAR	YR

ENGINE :	**MODEL**	KUBOTA V3800-T	**S/N**	2HA2612	
Oil leakage	(FAIR) ･ Attn		Oil	(FAIR) ･ Attn	
Blow-By	(FAIR) ･ Attn	A LITTLE ･ MIDDLE ･ SEVERE	Exhaust Color	(FAIR) ･ Attn	
Sound	(FAIR) ･ Attn		Radiator	(FAIR) ･ Attn	

GENERATOR					
RATED POWER	50 / 60 KVA		Leaking Breaker Condition	(FAIR) ･ Attn	
RATED AMPERE	144, 72.2 / 157, 78.7 A		Insulation Condition	(FAIR) ･ Attn	
Output Terminal	(FAIR) ･ Attn				

COMPRESSOR					
RATED PRESSURE	Mpa Kgf/cm2		Unload Condition	FAIR ･ Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR ･ Attn	
Compressor Oil Leak	FAIR ･ Attn		Safety Valve Condition	FAIR ･ Attn	

CONDITION	(FAIR) ･ Attn	

RUST(5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	TIRE WEAR	FAIR ･ WORN ･ UNEVEN WEAR

COMMENTS

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。