INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機･コンプレッサー･ウェルダー

INSPECTION DATE	2026/4/17	CATEGORY	(GENERATOR) / COMPRESSOR / WELDER		
MAKE	HOKUETSU		MODEL	SDG25LX-5B1	
SERIAL	P2CB1-0175		STAMP	NOT FOUND	
HR METER	13907 HR	TIRE SIZE		YEAR	YR

ENGINE :	MODEL	KUBOTA V2403	S/N	7HV8264
Oil leakage	(FAIR) · Attn		Oil	(FAIR) · Attn	
Blow-By	(FAIR) · Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	(FAIR) · Attn	
Sound	(FAIR) · Attn		Radiator	(FAIR) · Attn	

GENERATOR					
RATED POWER	20 / 25 KVA		Leaking Breaker Condition	(FAIR) · Attn	
RATED AMPERE	A		Insulation Condition	(FAIR) · Attn	
Output Terminal	(FAIR) · Attn				

COMPRESSOR					
RATED PRESSURE	Mpa Kgf/cm2		Unload Condition	FAIR · Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR · Attn	
Compressor Oil Leak	FAIR · Attn		Safety Valve Condition	FAIR · Attn	

CONDITION	(FAIR) · Attn	

RUST(5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	TIRE WEAR	FAIR ・WORN・ UNEVEN WEAR

COMMENTS

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。