INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機･コンプレッサー･ウェルダー

INSPECTION DATE	2026/5/7	CATEGORY	GENERATOR (COMPRESSOR) WELDER		
MAKE	AIRMAN		MODEL	PDS90SC	
SERIAL	71C5B11875		STAMP	NOT FOUND	
HR METER	UNKNOWN HR	TIRE SIZE		YEAR	YR

ENGINE :	MODEL	3LB1	S/N		
Oil leakage	(FAIR) · Attn		Oil	(FAIR) · Attn	
Blow-By	(FAIR) · Attn	A LITTLE · MIDDLE · SEVERE	Exhaust Color	(FAIR) · Attn	
Sound	(FAIR) · Attn		Radiator	(FAIR) · Attn	

GENERATOR					
RATED POWER	KVA		Leaking Breaker Condition	FAIR · Attn	
RATED AMPERE	A		Insulation Condition	FAIR · Attn	
Output Terminal	FAIR · Attn				

COMPRESSOR					
RATED PRESSURE	0.7 (Mpa) Kgf/cm2		Unload Condition	(FAIR) · Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	(FAIR) · Attn	
Compressor Oil Leak	(FAIR) · Attn		Safety Valve Condition	(FAIR) · Attn	

CONDITION	(FAIR) · Attn

RUST (5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	3	TIRE WEAR	FAIR · WORN · UNEVEN WEAR

COMMENTS

実HR不明 ACTUAL HR METER: UNKNOWN

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.
この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。