INSPECTION SHEET 検品書

GENERATOR / COMPRESSOR / WELDER 発電機･コンプレッサー･ウェルダー

INSPECTION DATE	2026/10/13	CATEGORY	(GENERATOR) / COMPRESSOR / WELDER		
MAKE	AIRMAN		MODEL	SDG400L-5B1	
SERIAL	PABB1-0133		STAMP	NOT FOUND	
HR METER	6615 HR	TIRE SIZE		YEAR	YR

ENGINE :	MODEL	6D140E-5	S/N	543888	
Oil leakage	FAIR ・(Attn)	*1	Oil	(FAIR) ・ Attn	
Blow-By	(FAIR) ・ Attn	A LITTLE ・ MIDDLE ・ SEVERE	Exhaust Color	(FAIR) ・ Attn	
Sound	(FAIR) ・ Attn		Radiator	(FAIR) ・ Attn	

GENERATOR					
RATED POWER	350 / 400 KVA		Leaking Breaker Condition	(FAIR) ・ Attn	
RATED AMPERE	A		Insulation Condition	(FAIR) ・ Attn	
Output Terminal	(FAIR) ・ Attn				

COMPRESSOR					
RATED PRESSURE	Mpa Kgf/cm2		Unload Condition	FAIR ・ Attn	
RATED AIR FLOW	m3/min		Receiver Tank Condition	FAIR ・ Attn	
Compressor Oil Leak	FAIR ・ Attn		Safety Valve Condition	FAIR ・ Attn	

CONDITION	(FAIR) ・ Attn	

RUST(5: NONE, 4: A LITTLE, 3: MIDDLE, 2: MUCH, 1: CORRODED)	5	TIRE WEAR	FAIR ・WORN・ UNEVEN WEAR

COMMENTS

*1 ベルトプーリー周り油漏れ小 AROUND PULLEY: OIL LEAKING

This inspection information is for reference only at "the inspection date" by SOGO. NOT to guarantee the condition of the actual machine.

この査定情報は『点検日時点』での参考資料であり、実際の機械の状態を保証するものではありません。